



Superior Quality, Superior Service and ONLY Fuels!

Certificate of Analysis

Laboratory Number: 101210053

John DeMartino
Ott's Friction Supply
201 N Columbia Blvd.
Portland, OR 97217 US
503-283-4165
Sample Taken From:
Sample ID:
PO:
WO:

Treated w/ Cold Flow Supplement
Verbal

Sample Collection Date:
Date Received: 10/12/2010
Date Released: 10/15/2010
Component Make:
Component Model:
Tank Capacity:
Quantity in Tank
Test Package
Type of Fuel: #2 Diesel

Test	Sample Result	Limits	Methods
Cloud Point	-31 °C	report °C	ASTM D2500-99
Pour Point	> -50 °C	report in °C	ASTM D97

These results are submitted pursuant to our terms, conditions and limitations and laboratory pricing policy.

No responsibility is assumed for the manner in which these results are used or interpreted.

901 W. Evergreen Blvd Suite 100 Vancouver, WA 98660 Phone: 360-546-3835